

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 60110047

Blatt *Page*
0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum <i>Date of Issue</i>	<i>(day/mo/yr)</i>
	0001--19600119 001	12.04.2016	

Genehmigungsinhaber *License Holder*

FLUCON COMPONENTS PRIVATE LIMITED
A-112, MIDC PHASE-1, ROAD NO:5&7
DOMBIVALI (E), THANE,
MAHARASHTRA-421203
India

Fertigungsstätte *Manufacturing Plant*

FLUCON COMPONENTS PRIVATE LIMITED
A-112, MIDC PHASE-1, ROAD NO:5&7
DOMBIVALI (E), THANE,
MAHARASHTRA-421203
India

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

EN 62275:2015

Zertifiziertes Produkt (Geräteidentifikation) *Certified Product (Product Identification)*

Lizenzentgelte - Einheit *License Fee - Unit*

Cable Tie

Type Designation:	FCCT-YYY X ZZ	5
	a) ZZ:2.0/YYY:065,080,100	1
	b) ZZ:2.5/YYY:100,150,200	1
	c) ZZ:3.2/YYY:150,200,250,300	1
	d) ZZ:3.6/YYY:150,200,250,300	1
	e) ZZ:4.8/YYY:200,250,300,350 368,400,450,550	1
	f) ZZ:7.6/YYY:200,300,380,450	1
	g) ZZ:7.9/YYY:500,550	1
	h) ZZ:9.0/YYY:650,750,920,1220	1
Trademark:	flu-con	
Min. Loop Tensile Strength:	a) 78.45N b) 98.07N c) 117.68N d) 176.52N e) 225.55N f) 343.23N g) 343.23N h) 588.40N	
Operating Temperature for Application:	0°C to .85°C	
Minimum Temperature During Installation:	(23±5)°C	

13

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

